

CSI: DIVISION: 07 00 00—THERMAL AND MOISTURE PROTECTION
Section: 07 21 00—Thermal Insulation

Product Certification System:

The ICC-ES product-certification system includes evaluating reports of tests of standard manufactured product, prepared by accredited testing laboratories and provided by the listee, to verify compliance with applicable codes and standards. The system also involves factory inspections, and assessment and surveillance of the listee's quality system.

Product: SLENTEX®

Listee: BASF CORPORATION

Evaluation: SLENTEX® is an aerogel insulating material and comes in a nominal thickness of 1-inch (25.4 mm) and density of 14.1 lb/ft³ (226 kg/m³) to the following standards:

- CAN/ULC-S114-05, Standard Method of Test for Determination of Non-Combustibility in Building Materials, Underwriters Laboratories of Canada.

Findings: SLENTEX® is classified as a noncombustible building construction material, based on testing in accordance with CAN/ULC-S114, as referenced in the applicable sections of the following code editions:

- *National Building Code of Canada*® 2015
Applicable Section: Volume 1, Division A, Section 1.4.1.2.(1)
- *National Building Code of Canada*® 2010
Applicable Section: Volume 1, Division A, Section 1.4.1.2.(1)

Identification:

1. SLENTEX® described in this listing report shall be identified by a stamp or label indicating the manufacturer's name (BASF Corporation) and address, the product name (SLENTEX®), the ICC-ES listing report number (ESL-1196), and the ICC-ES listing mark.
2. The report holder's contact information is the following:

BASF CORPORATION
1609 BIDDLE AVENUE
Wyandotte, Michigan 48192
(734) 324-5054
www.basf.com

Installation: The product must be installed in accordance with the BASF Corporation' published installation instructions and applicable codes.

Conditions of Listing:

1. The listing report addresses only conformance with the standard and code sections noted above.
2. Approval of the product's use is the sole responsibility of the local code official.
3. The listing report applies only to the materials tested and as submitted for review by ICC-ES.
4. SLENTEX® is manufactured in East Providence, Rhode Island under a quality control program with inspections by ICC-ES.